

# Certificate of Compliance

**Certificate Number:**

EX26837

**Report Reference:**

EX26837-2015-07-27

**Issue Date:**

2024-OCT-14

Issued to:

**VICTORY FIRE & GAS INC.  
1713 Lewis  
Bay City, MI 48706, USA**

This certificate confirms that representative samples of:

**GBAR – Dry-Chemical Extinguishers, Hand and Wheeled  
See Addendum Page for Product Designation(s).**

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**UL 299 – Dry Chemical Fire Extinguishers  
UL 711 – Rating and Test of Fire Extinguishers**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch  
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

# CERTIFICATE OF COMPLIANCE

**Certificate number**    EX26837  
**Report reference**     EX26837-2015-07-27  
**Date**                     2024-OCT-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

| Model                     | Category                                 | Nominal Agent Capacity, lb (kg) | Min Use Temp, F (C) | Class A Rating | Class B Rating | Class C Rating | Class K Rating | Marine Rating |
|---------------------------|--|---------------------------------|---------------------|----------------|----------------|----------------|----------------|---------------|
| PD10LB<br>PD10LB-AL       | Ammonium Phosphate, Stored-pressure-type | 10.5 (4.76)                     | -40 (-40)           | 4-A            | 60-B           | Yes            | No             | Yes           |
| PD10LB-S<br>PD10LB-ALS    | Ammonium Phosphate, Stored-pressure-type | 10.5 (4.76)                     | -40 (-40)           | 4-A            | 60-B           | Yes            | No             | No            |
| PD2.5LB<br>PD2.5LB-AL     | Ammonium Phosphate, Stored-pressure-type | 2.5 (1.13)                      | -40 (-40)           | 1-A            | 10-B           | Yes            | No             | Yes           |
| PD2.5LB-S<br>PD2.5LB-ALS  | Ammonium Phosphate, Stored-pressure-type | 2.5 (1.13)                      | -40 (-40)           | 1-A            | 10-B           | Yes            | No             | No            |
| PD20LB<br>PD20LB-AL       | Ammonium Phosphate, Stored-pressure-type | 20 (9.07)                       | -40 (-40)           | 6-A            | 80-B           | Yes            | No             | Yes           |
| PD20LBHF<br>PD20LBHF-A    | Ammonium Phosphate, Stored-pressure-type | 20 (9.07)                       | -40 (-40)           | 3-A            | 40-B           | Yes            | No             | Yes           |
| PD20LBHF-S<br>PD20LBHF-AS | Ammonium Phosphate, Stored-pressure-type | 20 (9.07)                       | -40 (-40)           | 3-A            | 40-B           | Yes            | No             | No            |
| PD20LB-S<br>PD20LB-ALS    | Ammonium Phosphate, Stored-pressure-type | 20 (9.07)                       | -40 (-40)           | 6-A            | 80-B           | Yes            | No             | No            |
| PD5LB<br>PD5LB-AL         | Ammonium Phosphate, Stored-pressure-type | 5 (2.27)                        | -40 (-40)           | 3-A            | 30-B           | Yes            | No             | Yes           |
| PD5LB-H<br>PD5LB-ALH      | Ammonium Phosphate, Stored-pressure-type | 5 (2.27)                        | -40 (-40)           | 3-A            | 40-B           | Yes            | No             | Yes           |
| PD5LB-HS<br>PD5LB-ALHS    | Ammonium Phosphate, Stored-pressure-type | 5 (2.27)                        | -40 (-40)           | 3-A            | 40-B           | Yes            | No             | No            |
| PD5LB-S<br>PD5LB-ALS      | Ammonium Phosphate, Stored-pressure-type | 5 (2.27)                        | -40 (-40)           | 3-A            | 30-B           | Yes            | No             | No            |



Trademark and/or Tradename: "VICTORY" ,

David Piecuch  
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



# Certificate of Compliance

**Certificate Number:**

EX26837

**Report Reference:**

EX26837-2025-03-07

**Issue Date:**

2025-MAR-07

Issued to:

**VICTORY FIRE & GAS INC.  
1713 LEWIS ST.  
BAY CITY, MI 48706 US**

This certificate confirms that representative samples of:

**Dry- Chemical Extinguishers Hand and Wheeled  
Certified for Canada**  
**See addendum for model information**

Has been evaluated by ULC Inc. in accordance with Standard(s) for Safety:

**ULC -S504 – Dry Chemical Extinguishers**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the ULC Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the ULC Mark.

Only those products bearing the ULC Mark should be considered as being ULC Certified and covered under UL's Follow-Up Services.

Look for the ULC Certification Mark on the product.



Gunsimar Paintal  
ULC Mark Certification Program Manager  
**Underwriters Laboratories of Canada Inc.**

Any information and documentation involving ULC Mark services are provided on behalf of Underwriters Laboratories of Canada Inc. (ULC) or any authorized licensee of ULC. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

# Certificate of Compliance

**Certificate Number:** EX26837  
**Report Reference:** EX26837-2025-03-07  
**Issue Date:** 2025-MAR-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

## Models

PD2.5LB, PD 5LB, PD10LB, PD20LB, PD2.5-AL, PD5LB-AL, PD10LB-1L, PD20LB-AL, PD5LB-ALH, PD5LB-H

Trademark and/or Tradename:

